

SUBMERSIBLE SOLIDS HANDLING PUMPS

3SC(X), 4SC(X) SERIES

RPM	3500			
MOTOR TYPE	PREMIUM EFFICIENT, IEC 60034 -30 LEVEL IE3 *			
MOTOR DESIGN NEMA TYPE	A or B (3Ø)			
GENERAL INSULATION CLASS	H			
STATOR WINDING CLASS	H			
MAXIMUM STATOR TEMPERATURE RATING	356°F (180°)			
MOTOR PROTECTION	3 PHASE, BI-METALLIC, TEMPERATURE SENSITIVE DISC, SIZED TO OPEN AT 130°C AND AUTOMATICALLY RESET @ 82°C DIFFERENTIAL			
ELECTRICAL RATINGS	HEAT SENSOR	24VDC 5 AMPS	115VAC 5AMPS	230VAC 5AMPS
	SEAL FAIL	300VAC 5mA		
VOLTAGE TOLERANCE	±10%			

*208V versions and 20/23HP models will not conform to IE3 standards.

HP	VOLTAGE	PHASE	NECCODE	SF	FULL LOAD AMPS	SF AMPS	LOCKED ROTOR AMPS	RUN KW	START KVA	RUN KVA	MTR. EFFICIENCY @100% FL	PWR. FACT. @SF	PWR. FACT. @100% FL	PWR. FACT. @75% FL	PWR. FACT. @50% FL	
15	208	3	K	1.15	44.7	49.8	365.0	14.4	131.3	16.1	91.0	89.9	89.3	87.5	83.2	
					230	40.4	45.0	330.0	14.4	131.3	16.1	91.0	89.9	89.3	87.5	83.2
					460	20.2	22.5	165.0	14.4	131.3	16.1	91.0	89.9	89.3	87.5	83.2
					575	16.2	18.0	135.0	14.4	134.3	16.1	91.0	89.9	89.3	87.5	83.2
20	208	3	H	1.15	57.5	66.3	365.0	18.7	131.3	20.7	91.0	89.8	90.1	89.3	86.4	
					230	52.0	60.0	330.0	18.7	131.3	20.7	91.0	89.8	90.1	89.3	86.4
					460	26.0	30.0	165.0	18.7	131.3	20.7	91.0	89.8	90.1	89.3	86.4
					575	21.3	24.0	135.0	18.7	134.3	21.2	91.0	89.8	90.1	89.3	86.4
23	230	3	G	1.0	60.0	60.0	330.0	21.4	131.3	23.9	91.0	-	89.8	89.9	87.6	
					460	30.0	30.0	165.0	21.4	131.3	23.9	91.0	-	89.8	89.9	87.6
					575	24.0	24.0	135.0	21.4	134.3	23.9	91.0	-	89.8	89.9	87.6

1101 Myers Parkway
Ashland, OH 44805
Ph: 855.274.8947
Fx: 800.426.9446

490 Pinebush Rd., Unit 4
Cambridge, Ontario N1T 0A5, Canada
Ph: 800.363.7867
Fx: 888.606.5484

pentair.com/hydromatic